


FTA1930

MARK^{III} Electric Fire Pump Controllers - Solid State Reduced Current Starting



| VOLTAGE/POWER TABLE | | | | | | | |
|----------------------------------|---------------------|--|--|--|--|--|--|
| LINE VOLTAGE | MOTOR HORSEPOWER | | | | | | |
| 208 | 5-30 | | | | | | |
| 220-240 | 5-30 | | | | | | |
| 380-400-415 | 5-60 | | | | | | |
| 440-480 | 5-60 | | | | | | |
| 600 | 5-75 | | | | | | |
| APPROX SHIPPING WEIGHT: 200 [91] | | | | | | | |

- 1. STANDARD: NEMA 2
- 2. STANDARD PAINT: TEXTURED RED RAL3002
- 3. ALL DIMENSIONS IN INCHES [MILLIMETERS]
- SHIPPING WEIGHT IN POUNDS [KG]
- 4. CENTER OF MARK III SCREEN: 29 5/8 [751] FROM BOTTOM OF ENCLOSURE (NO FEET)
- 5. BOTTOM CONDUIT ENTRANCE THROUGH
- REMOVABLE GLAND PLATE RECOMMENDED
- 6. USE WATERTIGHT CONDUIT AND CONNECTOR ONLY 7. PROTECT EQUIPMENT AGAINST DRILLING CHIPS
- 8. DOOR SWING EQUAL TO DOOR WIDTH
- 9. DRAWINGS FOR CONSTRUCTION PURPOSES
- MUST BE OBTAINED FROM FIRETROL OR THE LOCAL FIRETROL REPRESENTATIVE
- 10. SEISMIC MOUNTING TO BE RIGID WALL AND BASE ONLY

| | RELEASED | | | - | - | CIR | CIR | 11-5-19 | | | |
|---|-------------------|-----|---------|---|--|-----|----------------|-----------|----|-----------|------|
| THIRD ANGLE PROJECTION | size A | BY | DATE | | REVISION DESCRIPTION | | REV | ECN NO | BY | APP | DATE |
| | | | | | DIMENSIONS & SHIPPING WEIGHT FTA1930 DIGITAL SOLID STATE REDUCED CURRENT FIRE PUMP CONTROLLER | | DRAWING NUMBER | | | | |
| | DRAWN BY | CIR | 11-5-19 | | | | DD1930-70 | | | CDL | |
| | | | | | | | | | | | |
| | FINAL APPROVAL | CIR | 11-5-19 | | | | DWG REV - | ECN NO | | SHEET 1 O | |
| Al rights reserved. The drawing and the information contained or depicted herein are the sole property of Frietol, inc. Copies are communicated to the recipient in stirl confidence and may not be retransmitted, published, reproduced, copied or used in any manor, including as the basis for the manufacture or sale of any products, without the express prior written consent of Frietol, inc. | | | | | | | | | | | |