


MARK^{III} Limited Service Electric Fire Pump Controllers – Across The Line Starting


Control Terminals (EB1)

Terminals Wire Size:
24 - 12 AWG
0.5 Nm




Alarm Inputs (EB1)

Terminals Wire Size:
24 - 12 AWG
0.5 Nm




Remote Alarm Terminals (EB1)

Terminals Wire Size:
24 - 12 AWG
0.5 Nm





Network Connection (VMB1)

Shielded Female Connector RJ45



* Remove jumper to use this feature
** Re-assignable

Drawing for information only.
Manufacturer reserves the right to modify this drawing without notice.
Contact manufacturer for "As Built" drawing.

 THIRD ANGLE PROJECTION	SIZE	A	BY	DATE	<div>RELEASED</div>				-	-	CIR	CIR	11-12-19
	DRAWN BY	CIR	11-12-19	 Firetrol, Inc. © Firetrol, Inc. Not for construction. Subject to change without notice.	<div>REVISION DESCRIPTION</div>				REV	ECN NO	BY	APP	DATE
	FINAL APPROVAL	CIR	11-12-19		FIELD CONNECTIONS		FTA750		DRAWING NUMBER FC750-71				
	LIMITED SERVICE FIRE PUMP CONTROLLER								DWG REV -		ECN NO -	SHEET 1 OF 1	

ALL rights reserved. The drawings and the information contained or described herein are the sole property of Firetrol, Inc. Copies are communicated to the recipient in strict confidence and may not be retransmitted, published, reissued, copied or used in any manner, in whole or in part, as the basis for the manufacture or sale of any products, without the express prior written consent of Firetrol, Inc.

All rights reserved. The drawing and the information contained or depicted herein are the sole property of Firetrol, Inc. Copies are communicated to the recipient in strict confidence and may not be retransmitted, published, reproduced, copied or used in any manner, including as the basis for the manufacture or sale of any products, without the express prior written consent of Firetrol, Inc.