

Submittal Package FTA1500

Primary Resistor Starting

٦

STANDARD WITHSTAND RATINGS 200-600V - 100,000 Amps RMS Sym. INTERMEDIATE WITHSTAND RATINGS 200-600V - 150,000 Amps RMS Sym. HIGH WITHSTAND RATINGS 200-600V - 200,000 Amps RMS Sym.								
LINE VOLTAGE	MOTOR HORSEPOWER							
200	□ 3-60							
208	□ 3-60							
220–240	□ 3-60							
380-415	□ 3−100							
440–480	□ 3−100							
550-600	□ 3−100							

(DRAWINGS INCLUDED IN THIS PACKAGE ARE FOR STANDARD CONTROLLERS. ACTUAL "AS BUILT" DRAWINGS MAY DIFFER FROM THOSE SEEN HERE).

Firetrol, Inc.

3412 Apex Peakway Apex, North Carolina 27502 P 919 460-5200 F 919 460 5250 www.firetrol.com While every precaution has been take damages resulting from use of this int

While every precaution has been taken to ensure accuracy and completeness herein, Firetrol, Inc. assumes no responsibility, and disclaims all liability, for damages resulting from use of this information or for any errors or omissions. Specifications and drawings are subject to change without notice. ©2019 Firetrol, Inc., All Rights Reserved.

Firetrol Mark IIxg Electric Fire Pump Controller

FTA1500 - Primary Resistor Starting Specifications

1.0 Main Fire Pump Controller

The main fire pump controller shall be a factory assembled, wired and tested unit. The controller shall be of the combined manual and automatic type designed for primary resistor starting of the fire pump motor having the horsepower, voltage, phase and frequency rating shown on the plans and drawings.

1.1 Standards, Listings & Approvals

The controller shall conform to all the requirements of the latest editions of: NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection* NFPA 70, *National Electrical Code*.

The controller shall be listed by:

Underwriters Laboratories, Inc., in accordance with UL218, *Standard for Fire Pump Controllers* Canadian Standards Association CSA-C22.2, *Standard for Industrial Control Equipment* (cUL)

CÉ - Low Voltage Directive

The controller shall be approved by: Factory Mutual (IEC 62091) The City of New York for fire pump service

1.2 Enclosure

The controller components shall be housed in a NEMA Type 2 (IEC IP22) drip-proof, wall mounted enclosure.

1.3 Withstand Ratings (Short Circuit Current Ratings)

All controller components shall be front mounted, wired and front accessible for maintenance. The minimum withstand rating of the controllers shall not be less than 100,000 Amps RMS Symmetrical at 200-600 Volts*. If the available system fault current exceeds these ratings, the controllers shall be supplied with a withstand rating of 150,000 or 200,000 Amps RMS Symmetrical, as required.

*Note: 100,000 Amp withstand rating not available in some larger horsepowers. Consult factory for details.

1.4 Isolation Switch and Circuit Breaker

The controller shall include a motor rated combination isolating disconnect switch/circuit breaker, mechanically interlocked and operated with a single, externally mounted handle. When moving the handle from OFF to ON, the interlocking mechanism shall sequence the isolating disconnect switch ON first, and then the circuit breaker. When the handle is moved from ON to OFF, the interlocking mechanism shall sequence the circuit breaker OFF first, and then the isolating disconnect switch.

The isolating disconnect switch/circuit breaker shall be mechanically interlocked so that the enclosure door cannot be opened with the handle in the ON position except by a hidden tool operated bypass mechanism. The isolating disconnect switch/circuit breaker shall be capable of being padlocked in the OFF position for installation and maintenance safety, and shall also be capable of being locked in the ON position without affecting the tripping characteristics of the circuit breaker. The controller door shall have a locking type handle and three point cam and roller vault type hardware. The circuit breaker trip curve adjustment shall be factory set, tested and sealed for the full load amps of the connected motor. The circuit breaker shall be capable of being

field tested to verify actual pick up, locked rotor, and instantaneous trip points after field installation without disturbing incoming line and load conductors.

1.5 Operator Interface

The fire pump controller shall feature an operator interface with user keypad. The interface shall monitor and display motor operating conditions, including all alarms, events, and pressure conditions. All alarms, events, and pressure conditions shall be displayed with a time and date stamp. The display shall be a 128x64 Backlit LCD capable of customized graphics. The display and interface shall be NEMA rated for Type 2, 3R, 4, 4X, and 12 protection and shall be fully accessible without opening the controller door. The display and user interface shall utilize multiple levels of password protection for system security. A minimum of 3 password levels shall be provided.

1.6 Ammeter/Voltmeter

The fire pump controller operator interface shall be capable of displaying true RMS digital motor voltage and current measurements for all three phases simultaneously. Displays requiring push-button and selector switches to toggle between phases or current and voltage shall not be accepted.

Voltage and current shall be measured by True RMS technology to provide the most accurate measurement for all sine waves, including non-sinusoidal waveforms. Average responding meters will not be accepted.

1.7 Digital Status/Alarm Messages

The digital display shall indicate text messages for the status and alarm conditions of:

- Motor On
- Fail to Start
 Over Voltage
 Emergency Start
 Motor Overload
 Disk Near Full
 System Battery Low
 Locked Rotor Trip
 Motor Over 320%
 Disk Error
 Pressure Error
 Remote Start
 Under Voltage
 Over Frequency
 Drive Not Installed
 Printer Error

- Sequential Start Time
 Minimum Run Time

The Sequential Start Timer and Minimum Run Timer/Off Delay Timer shall be displayed as numeric values reflecting the value of the remaining time.

1.8 LED Visual Indicators

LED indicators, visible with the door closed, shall indicate:

- Power AvailableRemote StartAlarmPump RunningTransfer Switch Normal
- Transfer Switch Emergency

1.9 Data Logging

The digital display shall monitor the system and log the following data:

- Motor Calls/Starts
 Pump Total Run Time
- Total Controller Pwr On Time
- Min/Max System Pressure
- Last Locked Rotor Trip
 Last Locked Rotor Current
 Min/Max Frequency
- Max Starting Currents• Max Run Currents
- Min/Max Voltage per Phase while idle (not running)
 Min Voltage per Phase during Start
- Min/Max Voltage per Phase during Run

- System Pressure Low
- Deluge Open
- Phase Failure
- Phase Reversal
 Motor Overload
 Overvoltage
 Interlock On
 Emerg. Iso. Switch Off
 Undervoltage
 Fail To Start
 Automatic Shutdown Disabled
 - Pump Last Run Time
 - Last Pump Start
 - Last Phase Fail/Reversal

2.0 Event Recording

Memory - The controller shall record all operational and alarm events to system memory. All events shall be time and date stamped and include an index number. The system memory shall have the capability of storing 3000 events and allow the user access to the event log via the user interface. The user shall have the ability to scroll through the stored messages in groups of 1 or 10.

2.1 USB Host Controller

The controller shall have a built-in USB Host Controller. A USB port capable of accepting a USB Flash Memory Disk shall be provided. The controller shall save all operational and alarm events to the flash memory on a daily basis. Each saved event shall be time and date stamped. The total amount of historical data saved shall solely depend on the size of the flash disk utilized. The controller shall have the capability to save settings and values to the flash disk on demand via the user interface.

2.2 Serial Communications

The controller shall feature a RS485 serial communications port for use with 2 or 4 wire Modbus RTU communications.

2.3 Solid State Pressure Transducer

The controller shall be supplied with a solid state pressure transducer with a range of 0-300 psi (0-20.7 bar) ±1 psi. The solid state pressure switch shall be used for both display of the system pressure and control of the fire pump controller. Systems using analog pressure devices or mercury switches for operational control will not be accepted. The START, STOP and SYSTEM PRESSURE shall be digitally displayed and adjustable through the user interface. The pressure transducer shall be mounted inside the controller to prevent accidental damage. The pressure transducer shall be directly pipe mounted to a bulkhead pipe coupling without any other supporting members. Field connections shall be made externally at the controller coupling to prevent distortion of the pressure switch element and mechanism.

2.4 Controller Operation

A digitally set On Delay (Sequential Start) timer shall be provided as standard. Upon a call to start, the user interface shall display a message indicating the remaining time value of the On Delay timer.

The controller shall be field programmable for manual stop or automatic stop. If set for automatic stopping, the controller shall allow the user to select either a Minimum Run Timer or an Off Delay Timer. Both timers shall be programmable through the user interface.

A nonadjustable restart delay timer shall be provided to allow the residual voltage of the motor to decay prior to restarting the motor. At least 2 seconds, but no more than 3 seconds, shall elapse between stopping and restarting the pump motor.

A weekly test timer shall be provided as standard. The controller shall have the ability to program the time, date, and frequency of the weekly test. In addition, the controller shall have the capability to display a preventative maintenance message for a service inspection. The message text and frequency of occurrence shall be programmable through the user interface.

A Lamp Test feature shall be included. The user interface shall also have the ability to display the status of the system inputs and outputs.

An Audible Test feature shall be included to test the operation of the audible alarm device.

The controller shall not start the fire pump motor under a single-phase condition. If the motor is already running when a phase loss occurs, the controller shall continue to run the motor, but still display a Phase Failure alarm. The fire pump controller software shall be automatically upgraded through the USB port by simply inserting a flash disk with the new software. Fire pump controllers that require laptop computers, handheld equipment or specialized devices for software upgrades shall be prohibited.

2.5 Manufacturer

The controller shall be a Firetrol brand.

3412 Apex Peakway Apex, North Carolina 27502 P +1 919 460 5200 F +1 919 460 5250 www.firetrol.com While every precaution has been tak



While every precaution has been taken to ensure accuracy and completeness herein, Firetrol, Inc. assumes no responsibility, and disclaims all liability, for damages resulting from use of this information or for any errors or omissions. Specifications and drawings are subject to change without notice. ©2019 Firetrol, Inc., All Rights Reserved. Publication SP1500-50 Rev. G



Mark IIxg Electric Fire Pump Controllers

Product Description FTA1500

Primary Resistor Starting



Description—Firetrol® FTA1500 Primary Resistance Fire Pump Controllers use resistors in the line to reduce line voltage when starting the pump motor. The controller monitors, displays and records fire pump system information.

The circuit to the motor is not opened during the transition from start to run. While starting, the motor will draw 50% of full load starting current and supply 25% of rated torque. This method of starting minimizes line disturbances and voltage drop when starting.

Approvals – Firetrol fire pump controllers are listed by Underwriters' Laboratories, Inc., in accordance with UL218, *Standard for Fire Pump Controllers*, CSA, *Standard for Industrial Control Equipment*, and approved by Factory Mutual. They are built to meet or exceed the requirements of the approving authorities as well as NEMA and the latest editions of NFPA 20, *Installation of Centrifugal Fire Pumps*, and NFPA 70, *National Electrical Code.*

Standard Features—The following are included as standard with each controller:

- Voltage surge protector
- Main Disconnect Switch sized for connected motor horsepower and voltage
- Fire pump Circuit Breaker
- Single handle Isolating Disconnect Switch/ Circuit Breaker mechanism
- Motor contactor
- Emergency Manual Run Mechanism to mechanically close motor contactor contacts in an emergency condition
- Built-in Start and Stop push-buttons to bypass automatic start circuits
- Minimum Run Timer / Off Delay Timer
- Daylight Savings Time Option

- Weekly Test Timer
- Elapsed Time Meter
- Door mounted display/interface panel featuring a 128 x 64 pixel backlit LCD Graphical Display, Membrane Type User Control Pushbuttons and easy to read LED Indicators for:
 POWER AVAILABLE

 - ALARM
 - TRANSFER SWITCH NORMAL (If unit ordered with Automatic Power Transfer Switch)
 - TRANSFER SWITCH EMERGENCY (If unit ordered with Automatic Power Transfer Switch)
 - SYSTEM PRESSURE LOW
 - PUMP RUNNING
 - DELUGE OPEN
 - REMOTE START
 - INTERLOCK ON
 - FAIL TO START
 - MOTOR OVERLOAD
 - EMERGENCY ISO SWITCH OFF (If unit ordered with Automatic Power Transfer Switch)
 - PHASE FAILURE
 - PHASE REVERSAL
 - AUTOMATIC SHUTDOWN DISABLED
 - OVERVOLTAGE
 - UNDERVOLTAGE
- Digital Pressure Display
- USB Host Controller and Port
- Solid State Pressure Transducer
- Data Log
- Event Log (3000 Events)
- True RMS Metering with simultaneous 3 Phase Display of Amps, Volts, Frequency, Pressure and Alarm Messages
- Disk Error message
- Disk Near Full message
- Pressure Error message
- Motor Over 320% message
- Local Start message
- Remote Start message
- Emergency Start message
- Fail To Start message
- Undervoltage message
- Overvoltage message
- NEMA Type 2 (IEC IP22) enclosure
- Suitable for use as Service Equipment
- Each standard controller comes with user set options for:
 - Interlock Alarm Low Pressure Audible
 - Low Suction
 Pump Run
 - User Defined Input
 Weekly Test

SPECIAL ENCLOSURES

- Enclosure, NEMA Type 4 (IP66), Painted Steel -E
- -F Enclosure, NEMA Type 4X (IP66), #304 Stainless Steel, Brushed Finish
- -FD Enclosure, NEMA Type 4X (IP66), #316 Stainless Steel, **Brushed Finish**
- Enclosure, NEMA Type 4X (IP66), #316 Stainless Steel, -FDB 12 Gauge, Seam-Welded, Brushed Finish
- Enclosure, NEMA Type 4X (IP66), #316 Stainless Steel, -FDP Painted Finish
- -FXP Enclosure, NEMA Type 4X (IP66), #304 Stainless Steel, Painted Finish
- Enclosure, NEMA Type 12 (JP54), Painted Steel -G
- -T Enclosure, NEMA Type 3R (IP24), Painted Steel

CIRCUIT BREAKER OPTION

- Intermediate withstand rating -N
- 150,000 Amps RMS Sym. -P High withstand rating
- 200,000 Amps RMS Sym Intermediate and High withstand ratings may not Note: be available for all horsepowers and voltages. Consult factory for availability.

ANTI-CONDENSATION SPACE HEATERS

- Space Heater, 120V Externally Powered with -H Circuit Breaker
- Space Heater, 120V Externally Powered with Circuit -J Breaker and Thermostat
- Space Heater, 120V Externally Powered with Circuit -K Breaker and Humidistat
- Space Heater, 240V Externally Powered with -L **Circuit Breaker**
- Space Heater, 240V Externally Powered with Circuit -M Breaker and Thermostat
- -N Space Heater, 240V Externally Powered with Circuit Breaker and Humidistat

PRESSURE TRANSDUCERS

- Wetted Parts Including Pressure Sensor, 600 psi -B (42 Bar) Fresh Water
- Wetted Parts Including Pressure Sensor, 300 psi -C (21 Bar) Sea Water
- Wetted Parts Including Pressure Sensor, 600 psi -D (42 Bar) Fresh Water

COMBINED AUTOMATIC POWER TRANSFER SWITCHES

- FTA950 Automatic Transfer Switch, Group 5 -TSA -TSAB
- FTA951 Automatic Transfer Switch, J-Bypass Isolation, Group 5

ALARMS

- Alarm Output Contacts Extra, Pump Operating (1 -AC Form A, 1 Form B)
- Alarm, Audible/Visible, Low Pump Room Temperature Alarm, Audible/Visible, Reservoir Low -AF
- -AG
- Alarm, Audible/Visible, Low Suction Pressure -AH
- Alarm Output Contacts, Fail to Start -AM
- -AV Alarm Output Contacts, Low Pump Room Temperature (Requires option -AF)

- -AW Alarm Output Contacts, Reservoir Low (Requires option -AG)
- Alarm Output Contacts, Low Suction Pressure -AY (Requires option -AH)
- -BW Alarm Output Contacts, Phase Failure/Phase Reversal
- Alarm Output Contacts, Pump Overload -BY
- -COM Alarm, Audible/Visible/Output Contacts, Low Suction Pressure with Manual Reset Option, Pressure Switch Not Included (Do Not Use Options AH or AY)
- -CTS Alarm, Audible/Visible/Output Contacts, Low Suction Pressure Shutdown with Manual Reset Option and Pressure Switch (Do Not Use Options AH or AY)
- Alarm, Audible/Visible, Relief Valve Discharge -EG Alarm Output Contacts, Relief Valve Discharge -EH
- (Requires option -EG)
- Àlarm, Audible/Visible, Flow Meter On -FJ
- -EK Alarm Output Contacts, Flow Meter On (Requires option -EJ)
- -KH Alarm Output Contacts, Common Alarm
- Visible Indicator, Jockey Pump Operating -JR
- Alarm, Audible/Visible, Jockey Pump Trouble - IT
- -P Alarm, Audible/Visible, Built-In 120V Supervisory System (Includes visible supervisory voltage normal indication and audible pump operating, phase failure and phase reversal indication)
- -PE Alarm Output Contacts, Low System Pressure (pump on demand)
- Ålarm, Audible/Visible, Built-in 240V Supervisory -PT System (Includes visible supervisory voltage normal indication and audible pump operating, phase failure and phase reversal indication)

MISCELLANEOUS

- Thermostat, Low Pump Room Temperature, -AZ Mounted and Wired
- Output Contacts, Load Shed (Selectable power -FD source and adjustable time delay to remove noncritical loads before starting)
- -EL Series Pumping Operation, High Zone Controller
- -EM Series Pumping Operation, Mid Zone Controller
- Series Pumping Operation, Low Zone Controller -EN
- Rating, Nameplate to be marked 380-400V (Use -FZX with voltage code 'F' or 'FZ')
- -IEC Marking, CE with External Wet Parts (Requires NEMA Type 12 (IP54) Enclosure as minimum)
- Marking, CE with Internal Wet Parts (Requires NEMA -IECI Type 12 (IP54) Enclosure as minimum)
- Neutral Lug, Service Entrance, Non-insulated -MZN Bonded to Enclosure
- Terminal Blocks, Extra Remote Start -PK
- -PY Output Contacts, Motor Space Heater Circuit, Externally Powered
- -S Tropicalization
- -USBX Data Port, External USB
- Scheduled Service Message (when factory pro--ZPA grammed or programmed by Firetrol representative during start-up)
- -ZPM Data Port, Serial Modbus RTU Over 2-Wire or 4-Wire RS485
- -ZPN Data Port, Serial Modbus RTU Over Ethernet TCP/IP


Export packaging (Wooden crating to conform to IPPC Standards)

Firetrol, Inc.

3412 Apex Peakway Apex, North Carolina 27502 P +1 919 460 5200 F +1 919 460 5250 www.firetrol.com

While every precaution has been taken to ensure accuracy and completeness herein. Firetrol, Inc. assumes no responsibility, and disclaims all liability, for damages resulting from use of this information or for any errors or omissions. Specifications and drawings are subject to change without notice. @2019 Firetrol, Inc., All Rights Reserved.





SPECIAL ENCLOSURES

- Enclosure, NEMA Type 4 (IP66), Painted Steel -E
- -F Enclosure, NEMA Type 4X (IP66), #304 Stainless Steel, **Brushed Finish**
- -FD Enclosure, NEMA Type 4X (IP66), #316 Stainless Steel, **Brushed Finish**
- -FDB Enclosure, NEMA Type 4X (IP66), #316 Stainless Steel, 12 Gauge, Seam-Welded, Brushed Finish
- -FDP Enclosure, NEMA Type 4X (IP66), #316 Stainless Steel, Painted Finish
- Enclosure, NEMA Type 4X (IP66), #304 Stainless Steel, -FXP Painted Finish
- Enclosure, NEMA Type 12 (IP54), Painted Steel -G
- Enclosure, NEMA Type 3R (IP24), Painted Steel -T

CIRCUIT BREAKER OPTION

- Intermediate withstand rating -N
- 150,000 Amps RMS Sym. -P High withstand rating
- 200,000 Amps RMS Sym Note: Intermediate and High withstand ratings may not be available for all horsepowers and voltages. Consult factory for availability.

ANTI-CONDENSATION SPACE HEATERS

- -H Space Heater, 120V Externally Powered with Circuit Breaker
- Space Heater, 120V Externally Powered with Circuit -.1 Breaker and Thermostat
- -K Space Heater, 120V Externally Powered with Circuit Breaker and Humidistat
- Space Heater, 240V Externally Powered with Circuit -1 Breaker
- Space Heater, 240V Externally Powered with Circuit -M Breaker and Thermostat
- -N Space Heater, 240V Externally Powered with Circuit Breaker and Humidistat

PRESSURE TRANSDUCERS

- 0-600 psi (0-42.25 bar) Pressure Transducer for -B Fresh Water Service
- 0-300 psi (0-21.1 bar) Pressure Transducer for -C Copper Corrosive Service
- -D 0-600 psi (0-42.25 bar) Pressure Transducer for Corrosive Service

COMBINED AUTOMATIC POWER TRANSFER SWITCHES

- FTA950 Automatic Transfer Switch, Group 5 -TSA
- -TSAB FTA951 Automatic Transfer Switch, J-Bypass Isolation, Group 5

ALARMS

- Alarm Output Contacts Extra, Pump Operating (1 -AC Form A, 1 Form B)
- Alarm, Audible/Visible, Low Pump Room Temperature -AF
- Alarm, Audible/Visible, Reservoir Low -AG
- -AH Alarm, Audible/Visible, Low Suction Pressure
- Alarm Output Contacts, Fail to Start -AM
- -AV Alarm Output Contacts, Low Pump Room Temperature (Requires option -AF)
- -AW Alarm Output Contacts, Reservoir Low (Requires option -AG)
- -AY Alarm Output Contacts, Low Suction Pressure (Requires option -AH)

Firetrol, Inc.

3412 Apex Peakway Apex, North Carolina 27502

- P +1 919 460 5200
- F +1 919 460 5250
- www.firetrol.com

- -BW Alarm Output Contacts, Phase Failure/Phase Reversal
- Alarm Output Contacts, Pump Overload -BY
- Alarm, Audible/Visible/Output Contacts, Low Suc--COM tion Pressure with Manual Reset Option, Pressure Switch Not Included (Do Not Use Options AH or AY)
- -CTS Alarm, Audible/Visible/Output Contacts, Low Suction Pressure Shutdown with Manual Reset Option and Pressure Switch (Do Not Use Options AH or AY)
- -EG Alarm, Audible/Visible, Relief Valve Discharge
- Alarm Output Contacts, Relief Valve Discharge -EH (Requires option -EG)
- -F I Alarm, Audible/Visible, Flow Meter On
- Alarm Output Contacts, Flow Meter On (Requires -EK option -EJ)
- -KH Alarm Output Contacts, Common Alarm
- -JR Visible Indicator, Jockey Pump Operating
- Alarm, Audible/Visible, Jockey Pump Trouble -JT
- Alarm, Audible/Visible, Built-In 120V Supervisory Sys--P tem (Includes visible supervisory voltage normal indication and audible pump operating, phase failure and phase reversal indication)
- -PE Alarm Output Contacts, Low System Pressure (pump on demand)
- -PT Alarm, Audible/Visible, Built-in 240V Supervisory System (Includes visible supervisory voltage normal indication and audible pump operating, phase failure and phase reversal indication)

MISCELLANEOUS


- Thermostat, Low Pump Room Temperature, Mount--AZ ed and Wired
- -FD Output Contacts, Load Shed (Selectable power source and adjustable time delay to remove noncritical loads before starting)
- -FI Series Pumping Operation, High Zone Controller
- Series Pumping Operation, Mid Zone Controller Series Pumping Operation, Low Zone Controller -FM
- -FN
- -FZX Rating, Nameplate to be marked 380-400V (Use with voltage code 'F' or 'FZ')
- -IEC Marking, CE with External Wet Parts (Requires NEMA Type 12 (IP54) Enclosure as minimum)
- Marking, CE with Internal Wet Parts (Requires NEMA -IECI Type 12 (IP54) Enclosure as minimum)
- -OSP OSHPD Seismic Certification (State of California) (Requires Option -SEI)
- Neutral Lug, Service Entrance, Non-insulated -MZN Bonded to Enclosure
- -PK Terminal Blocks, Extra Remote Start
- -PY Output Contacts, Motor Space Heater Circuit, Externally Powered
- Tropicalization -S
- -SEI Marking, Seismic Certified (in accordance with IBC) (Note: Not available on model FTA1500)
- Data Port, External USB -USBX
- -ZPA Scheduled Service Message (when factory programmed or programmed by Firetrol representative during start-up)
- -ZPM Data Port, Serial Modbus RTU Over 2-Wire or 4-Wire RS485
- -ZPN Data Port, Serial Modbus RTU Over Ethernet TCP/IP


Export packaging (Wooden crating to conform to IPPC Standards) FTA1000 - 1930



General Starting Configuration FTA1500

Primary Resistor Starting





% Synchronous Speed


Firetrol, Inc. 3412 Apex Peakway Apex, North Carolina 27502 P +1 919 460 5200 F +1 919 460 5250 www.firetrol.com While every precaution has been taken to ensure accuracy and completeness herein, Firetrol, Inc. assumes no responsibility, and disclaims all liability, for damages result-ing from use of this information or for any errors or omissions. Specifications and drawings are subject to change without notice. ©2019 Firetrol, Inc., All Rights Reserved.

Publication GS1500-01 Rev. C



THIRD ANGLE PROJECTION

Mark IIxg Electric Fire Pump Controllers



					UPDATED TITLE BLOCK			281057	JMW	TEF	09-25-19	
					ADDED COMPONENTS TO MEET FM REQUIR	В	228552	JC	TEF	08-11-10		
Ι	size A	BY	DATE		REVISION DESCRIPTION		REV	ECN NO	BY	APP	DATE	
·	DRAWN BY	TEF	07-19-02	F Firetrol, Inc.	DIMENSIONS AND SHIPPING WEIGHT	FTA1500	DRAWING NUMBER					
l		101	01 10 02					DD1500-52				
	FINAL APPROVAL	TEF	07-19-02	© Firetrol, Inc. Not for construction. Subject to change without notice.	PRIMARY RESISTOR FIRE PUMP CONTROLLER		DWG REV C	ECN 281057		Sł	HEET 1 OF 1	
18	drawing and the in	drawing and the information contained or depicted herein are the sole property of Firetrol, Inc. Copies are communicated to the recipient in strict confidence and may not be retainsmitted, published, reproduced, copied or used in any manor, including as the basis for the manufacture or sale of any products, without the express prior written consent of Firetrol, Inc.										

Dimensions and Shipping Weight FTA1500 Primary Resistor Starting



NORMALLY OPEN, CLOSES TO ALARM

TO PHASE

REVERSAL REMOTE

ALARM CIRCUITS

TO PUMP OPERATING REMOTE ALARM CIRCUITS

TO POWER/PHASE FAILURE REMOTE

ALARM CIRCUITS

REMOTE ALARM TERMINAL BLOCKS


26


25


5CR

Field Connections FTA1500

Primary Resistor Starting







NOTE:	TERMINALS FOR	CUSTOMER	CONNECTIONS	REQUIR

TERMINAL TYPE	WIRE SIZE	TIGHTENING TORQUE
CONTROL AND ALARM TERMINALS	#14-12 AWG [2.5-4 MM ²]	5.6 lb—in [.6 Nm]

PRESSURE SYSTEM CONNECTION 1/2" FNPT


-NOTE-
ALARM CONTACT
RATING PILOT DUTY
250 VAC, 30 VDC
10 A. MAX. LOAD

					UPDATED TITLE BLOCK		В	281057	JMW	TEF	10-02-19
					ADD NOTE FOR COPPER CONDUCTORS ONLY, UPDATED LOGO & TITLE BLOCK			226253	JC	TEF	12-09-09
	SIZE A BY DATE		REVISION DESCRIPTION		REV	ECN NO	BY	APP	DATE		
	DRAWN BY TEF (TEE	05-04-02	Firetrol, Inc.	FIELD CONNECTIONS	FTA1500			<u></u>		
THIRD ANGLE		00 04 02		PRIMARY RESISTOR FIRE PUMP CONTROLLER			- FC1500-50				
PROJECTION	FINAL APPROVAL	TEF	05-04-02	© Firetrol, Inc. Not for construction. Subject to change without notice.	PRIMARY RESISTOR FIRE PUMP CONTROLLER		$_{\text{REV}}^{\text{DWG}}$ B	NO 28	1057	Sł	HEET 1 OF 2
All rights recorded. Th	a drawing and the in	formation co	hatsigab so bagistad	perein are the sole property of Firetrol. Inc. Conjee are communicated to the re	cinient in strict confidence and may not be retransmitted, published, reproduced, con-	iad or used in any manor, induction as the basis for the manufacture or	eals of any produc	te without the eve	rose orior	witten cor	neent of Eirstrol Inc.



Field Connections FTA1500

Primary Resistor Starting





Field Connections FTA1500

Primary Resistor Starting Line & Motor Wire Terminal Capacity

LINE TERMINALS-WIRE CAPACITY AND QUANTITY (CU)

200V	MAXIMUM MOTOR HORSEPOWER WIRE SIZE (CU) V 208V 220-240V 380-415V 440-480V 550-600V PER_PHASE			WIRE SIZE SERVICE ENTRANCE GROUND LUG (CU)								
25	25	30	50	60	75	(1) #14 AWG-#1/0 AWG (1) 2.5 MM ² -50 MM ²	(2) #14 AWG-#2/0 AWG (2) 2.5 MM ² -70 MM ²					
30	30	40	60	75	100	(1) #2 AWG-#4/0 AWG (1) 35 MM ² -100 MM ²	(2) #14 AWG-#2/0 AWG (2) 2.5 MM ² -70 MM ²					
50	50	60	100	125		(1) #4 AWG-300 kcmil (1) 25 MM ² -150 MM ²	(2) #14 AWG-#2/0 AWG (2) 2.5 MM ² -70 MM ²					
60	75	75	125	150	200	(1) #6 AWG-350 kcmil (1) 16 MM ² -185 MM ²	(2) #6 AWG-250 kcmil (2) 16 MM ² -120 MM ²					
100	100	100	150	250	300	(1) 250 kcmil-500 kcmil (1) 120 MM ² -240 MM ²	(2) #6 AWG-250 kcmil (2) 16 MM ² -120 MM ²					
	125	125	200		350	(2) #3/0 AWG-250 kcmil (2) 95 MM ² -120 MM ²	(2) #6 AWG-250 kcmil (2) 16 MM ² -120 MM ²					
250	250	250	400	500	700	(3) #2/0 AWG-400 kcmil (3) 70 MM ² -200 MM ²	(2) #6 AWG-250 kcmil (2) 16 MM ² -120 MM ²					
		300	500	600		(4) #4/0 AWG-500 kcmil (4) 100 MM ² -240 MM ²	(2) #6 AWG-250 kcmil (2) 16 MM ² -120 MM ²					

MOTOR TERMINALS-WIRE CAPACITY AND QUANTITY (CU) $\langle 1 \rangle$

	MAX	WIRE SIZE (CU)				
200V	208V	220-240V	380-415V	440-480V 550-60		PER PHASE
30	30	40	60	75	100	(1) #6 AWG-#2/0 AWG (1) 16 MM ² -70 MM ²
50	50	60	75	125	150	(1) #6 AWG-250 kcmil (1) 16 MM ² -120 MM ²
75	75	100	150	200	250	(1) #4 AWG-400 kcmil (1) 25 MM ² -200 MM ²
100	100			250	300	(2) #4 AWG-500 kcmil (2) 25 MM ² -240 MM ²
200	200	200	350	500	600	(2) 250 kcmil-500 kcmil (2) 120 MM ² -240 MM ²
250	250	300	500	600	700	(3) #2/0 AWG-500 kcmil (3) 70 MM ² -240 MM ²

FOR CORRECT WIRE SIZING, REFER TO *NATIONAL ELECTRICAL CODE*, NFPA 70.


WHEN REQUIRED BY AUTHORITY HAVING JURISDICTION.

(2)

 $\langle 1 \rangle$

					UPDATED TITLE BLOCK		В	281057	JMW	TEF	10-02-19
					UPDATED LOGO AND TITLE BLOCK		А	226994	JC	TEF	12-09-09
		REVISION DESCRIPTION		REV	ECN NO	BY	APP	DATE			
	DRAWN BY TEE	3Y TEF 05-06-02		Firetrol, Inc.	FIELD CONNECTIONS	FTA1500	DRAWING NUMBER				
THIRD ANGLE	DIGUNUDI	IEF	00-00-02		PRIMARY RESISTOR FIRE PUMP CONTROLLER			- FC1500-51			
	FINAL APPROVAL	TEF	05-06-02	© Firetrol, Inc. Not for construction. Subject to change without notice.	LINE AND MOTOR FIELD WIRE TERMINAL CAPACITY		DWG REV B	WG B NO 281057			HEET 1 OF 1





Wiring Schematic FTA1500

Primary Resistor Starting

LOCK	E	281057	JMW	TEF	10-02-19				
NOID AND AUDIBLE ALARM			228528	JC	TEF	08-30-10			
ION			ECN NO	BY	APP	DATE			
ATIC	FTA1500	DRAWING NUMBER WS1500-50							
				7 100-50					
FOR FIRE PUMP CONTROLLER		dwg rev E	ECN 281057 SHEE			HEET 1 OF 1			

PRIMARY RESIS

© Firetrol, Inc. Not for construction.

Subject to change without notice.

F**IN**AL APPROVAL

TEF

05-10-02