




Remote Alarm Panels For Use With Diesel Engine Fire Pump Controllers



SPECIAL ENCLOSURES

Option	Description
---	Enclosure, NEMA Type 1 (IP20), Painted Steel (Standard)
-Q	Enclosure, NEMA Type 2 (IP22), Painted Steel
-EX	Enclosure, NEMA Type 4 (IP65), Painted Steel
-F	Enclosure, NEMA Type 4X (IP66), #304 Stainless Steel, Brushed Finish
-FXP	Enclosure, NEMA Type 4X (IP66), #304 Stainless Steel, Painted Finish

Optional Alarms

Option	Description
-AV	Alarm, Audible/Visible, Low Pump Room Temperature
-AW	Alarm, Audible/Visible, Reservoir Low
-AY1	Configurable Low Suction Pressure Visible/Output Contacts with External Digital Input
-AK	Alarm, Audible/Visible, Low Oil Pressure
-AL	Alarm, Audible/Visible, High Water Temperature
-AM	Alarm, Audible/Visible, Fail To Start
-API	Alarm, Audible/Visible, Main Switch In Manual
-AR	Alarm, Audible/Visible, Main Switch In Off
-AS1	Alarm, Audible/Visible, Main Switch In Auto
-BTC	Alarm Output Contacts, Charger #1 & #2 Failure (Form-C, SPDT)
-CFC	Alarm Output Contacts, Battery #1 & #2 Failure (Form-C, SPDT)
-LC	Alarm, Audible/Visible, High Fuel Level
-LE1	Alarm, Audible/Visible, Fuel Spill
-Y	Alarm, Specify Number Of Alarms, Function of Each & Nameplate Marking

Miscellaneous

Option	Description
-BA	AC Input, 220-240V
-BS	Fire Pump Start Push-button

Firetrol, Inc.

3412 Apex Peakway
 Apex, North Carolina 27502
 P +1 919 460 5200
 F +1 919 460 5250
 www.firetrol.com

While every precaution has been taken to ensure accuracy and completeness herein, Firetrol, Inc. assumes no responsibility, and disclaims all liability, for damages resulting from use of this information or for any errors or omissions. Specifications and drawings are subject to change without notice. ©2019 Firetrol, Inc., All Rights Reserved.