

# CERTIFICATE OF COMPLIANCE

**Certificate Number** A-E510132  
**Report Reference** E510132-20050324  
**Issue Date** 2020-JANUARY-28

**Issued to:** Firetrol Inc  
3412 Apex Peakway  
Apex NC 27502

**This certificate confirms that  
representative samples of**

**FIRE PUMP CONTROLLERS FOR USE IN HAZARDOUS  
LOCATIONS**

Fire Pump Controllers for use in Class I, Division 2, Groups C and D Hazardous Locations.

Model FTA-1100 followed by -HR, -HS, -HV, -HW or -HX, or -HY followed by 12 or 24, followed by L or N, followed by P or N, may be followed by additional suffixes.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

ANSI/ISA 12.12.01-2012, Nonincendive Electrical Equipment for use in Class I and II, Division 2 and Class III Divisions 1 and 2 Hazardous (Classified) Locations  
UL 1236, Engine Starter Battery Chargers  
UL508, Industrial Control Equipment

**Additional Information:**

See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

