

CERTIFICATE OF COMPLIANCE

Certificate Number A-EX28191
Report Reference EX28191-19871023
Issue Date 2020-JANUARY-28

Issued to: Firetrol Inc
3412 Apex Peakway
Apex NC 27502

This certificate confirms that representative samples of PUMP CONTROLLERS, FIRE, OVER 600 VOLTS
See Addendum

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL218, Fire Pump Controllers
UL347, High Voltage Industrial Control Equipment
NFPA20, Installation of Stationary Pumps for Fire Protection
UL508 & CSA C22.2 No. 14, Standard for Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number A-EX28191
Report Reference EX28191-19871023
Issue Date 2020-JANUARY-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fire pump controller rated in excess of 600 V for controlling an electric motor for driving a fire pump.

Full Voltage Starting Model FTA2000 followed by A, B or C followed by H, followed by a three or four digit number not to exceed 3500 followed by K, J, L, M, N, P, Q, or R may be followed by additional letters.

Primary Rector Model FTA2400 followed by A, B, or C, followed by H, followed by a three or four digit number not to exceed 3500, followed by J, K, L, M, N, P, Q or R, may be followed by additional letters.


Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

