



- NOTES**
1. NORMALLY OPEN, CLOSURES TO ALARM CIRCUIT
 2. NORMALLY CLOSED, OPENING TO ALARM CIRCUIT
 3. FOR PILOT CIRCUIT, 100VAC, 10A, MAX. LOAD
 4. ALL CONTACTS SHOWN DE-ENERGIZED
 5. TERMINALS H AND N RATED 100VA, 120VAC MAX. LOAD
 6. REFER TO TRANSFORMER NAMEPLATE FOR CONNECTION INFORMATION
 7. TO PUMP RUNNING REMOTE ALARM CIRCUITS
 8. TO PHASE/POWER FAILURE REMOTE ALARM CIRCUITS
 9. RELAY TERMINALS H AND N CONTACT IS USED FOR SHUTDOWN INTERLOCK
 11. SPARE TERMINAL PROVIDED FOR PARALLEL CONNECTION OF REMOTE ALARMS (IF REQUIRED)

THIRD ANGLE PROJECTION	SIZE	B	BY	DATE
	DRAWN BY	TEF	05-10-02	
	FINAL APPROVAL	TEF	05-10-02	

Firetrol, Inc.
 © Firetrol, Inc. Not for construction.
 Subject to change without notice.

UPDATED TITLE BLOCK		E	280937	JMW	TE	09-20-19
ADDED TEST SOLENOID AND AUDIBLE ALARM		D	228528	JC	TEF	08-30-10
REVISION DESCRIPTION		REV	ECN NO	BY	APP	DATE
WIRING SCHEMATIC		FTA1350		DRAWING NUMBER		
CLOSED TRANSITION WYE-DELTA FIRE PUMP CONTROLLER				WS1350-50		
DWG REV	E	ECN NO	280937	SHEET 1 OF 1		

All rights reserved. The drawing and the information contained or depicted herein are the sole property of Firetrol, Inc. Copies are communicated to the recipient in strict confidence and may not be retransmitted, published, reproduced, copied or used in any manner, including as the basis for the manufacture or sale of any products, without the express prior written consent of Firetrol, Inc.